



Reliance Infrastructure Limited (RInfra-G)
Dahanu Thermal Power Station
Fuel Details for the month of September 2017 (As per Regulation 48.6 of MYT Regulations, 2015)

S. No.	Particulars	Units	Sep-17
1	Fuel parameters (for each primary and secondary fuel)		
1.1	Calorific Value (Received)		
1.1.1	Weighted Average GCV (Blended Coal as received)		3673
1.1.2	Fuel 1 (Washed Coal)	kcal/Kg	3673
1.1.3	Fuel 3 (Imported Coal)	kcal/Kg	4249
1.1.4	Fuel 4 (LDO)	kcal/Kg	10724
1.2	Calorific Value (fired)		
1.2.1	Weighted Average GCV (Blended Coal as fired)	kcal/Kg	3565
1.2.2	Fuel 1 (Washed Coal)	kcal/Kg	3565
1.2.3	Fuel 3 (Imported Coal)	kcal/Kg	4099
1.2.4	Fuel 4 (LDO)	kcal/Kg	10724
1.3	Stacking Loss	kcal/Kg	
1.3.1	Weighted Average Stacking Loss	kcal/Kg	108.00
1.3.2	Fuel 1 (Washed Coal)	kcal/Kg	108.00
1.3.3	Fuel 3 (Imported Coal)	kcal/Kg	0.00
1.3.4	Fuel 4 (LDO)	kcal/Kg	0.00
1.4	Landed Fuel Price per unit		
1.4.1	Fuel 1 (Washed Coal)	Rs./MT	4549.07
1.4.2	Fuel 3 (Imported Coal)	Rs./MT	0
1.4.3	Fuel 4 (LDO)	Rs./MT	42155.89
1.5	Blending Ratio		
1.5.1	Washed coal in primary fuel blend	%	100.00%
1.5.2	Imported coal in primary fuel blend	%	0%

Note:

- 1 In case of domestic washed coal, as fired GCV is mix of coal received during the month and the coal fired from
- 2 No imported coal received in September 2017. The GCV, both, as received and as fired, measured from identified stockpiles of imported coal is considered.
- 3 E-Auction coal - NIL